

APPENDIX A

Clarington Energy Business Park Heating and Cooling Loads

DRAFT

**Durham/York Thermal Treatment Facility
Energy and Associated Impacts Report
Appendix A - Clarington Energy Business Park Heating and Cooling Loads**

Clarington Energy Business Park Peak Thermal Loads

Land Development Criteria	Surface Area		PEAK ⁽¹⁾ Thermal Load (MWth) ^(2,3)	
	m ²	sf	Cooling	Heating
prestige employment	1,275,000	13,716,960	62.5	74.0
light industrial	363,000	3,905,299	17.8	21.1
<i>Total</i>	<i>1,638,000</i>	<i>17,622,259</i>	<i>80.3</i>	<i>95.0</i>

Clarington Energy Business Park Annual Thermal Loads and Energy Displacement

Month	Degree Days (5) (<18C)	Daily Average (5) degrees C	AVERAGE Thermal Load ⁽⁶⁾	
			Cooling kWth	Heating kWth
Jan	752.9	-6.3	-	64,148
Feb	662.1	-5.4	-	53,695
Mar	571.6	-0.4	-	37,956
Apr	353.3	6.3	-	22,404
May	171.8	12.9	10,246	11,467
Jun	49.4	17.8	31,592	2,928
Jul	8.9	20.8	44,827	1,970
Aug	17.8	19.9	40,558	1,970
Sep	102.5	15.3	22,200	6,659
Oct	282.6	8.9	-	17,620
Nov	445.5	3.2	-	28,821
Dec	647.4	-2.9	-	46,147
year	4065.7	7.5		
Annual Total Thermal Load (MWh)			119,565	224,828
Displaced Utilities			electricity	natural gas
Displaced Consumption (m ³ /yr)			-	26,987,432
Displaced Consumption (MWhr/yr)			19,927	-
Displaced Equipment			electric chillers	boilers
Efficiency			-	80%
COP			6	-

NOTES

1 Weather Conditions

ASHRAE Toronto	degrees C
99% cooling condition	35
99% heating condition	-20

Building	Est'd mix (4) %	Cooling	Heating
		W/m ² at 35C	W/m ² at -20C
Poor insulation	0%	37	80
Medium Insulation	0%	43	69
Good Insulation	100%	49	58
<i>composite</i>		49.0	58.0
<i>equivalent peak load</i>		1489.0	2163.0

- 3** Industrial process loads are not included, but presumed to be minimal.
Reference to Data Processing Centres is important for consideration of significant cooling loads.
- 4** Building mix selection is estimated.
- 5** Toronto Pearson Int'l Airport Norms (Environment Canada Website, April 20, 2009) for 1971 to 2000.
- 6** Retscreen Load and Network Design.

