

DYEC AMESA – Investigation Checklist

SAMPLE VERIFICATION	
Date (DD/MM/YYYY)	
_____	Verify date of receipt of XAD traps and hardware
_____	Verify installation date for XAD trap and hardware
_____	Verify removal date for XAD trap and hardware
_____	Verify date XAD trap and hardware received at the test lab
_____	Verify date XAD trap processed at the test lab
LAB FACTORS	
<input type="checkbox"/>	Review proof certificate from lab
Y / N	Is lab proof <20 pgTEQ for the monthly sample? Value _____
DATA CALCULATION FACTORS	
<input type="checkbox"/>	Check AMESA flow report for test period and confirm correct period
<input type="checkbox"/>	Confirm calculations leading to table of TEQ's
AMESA FACTORS	
<input type="checkbox"/>	Review AMESA measurement summary log (unusual events or alarms)
Y / N	Review AMESA logbook for maintenance activities performed or issues noted. Has the AMESA chiller operated within acceptable limits? Y/N If No: _____
Y / N	AMESA operating in non-isokinetic conditions (black plant) If YES, provide reason: _____ _____ _____ _____
Y / N	AMESA chiller operating nominally and holding the correct temperature setpoint Temperature SP: _____ °C
Y / N	Were there any AMESA system faults during the run?

OPERATIONAL FACTORS	
	Gather paper based operational data for the period of investigation
<input type="checkbox"/>	Shift Supervisor log
<input type="checkbox"/>	CRO log
	Review Operational Data for the period of investigation
<input type="checkbox"/>	Review boiler feed stops
<input type="checkbox"/>	Review any boiler cleaning activities
<input type="checkbox"/>	Review combustion trends
<input type="checkbox"/>	Review Combustion Trends

DYEC AMESA – Investigation Checklist

OPERATIONAL FACTORS	
	Tertiary Air Operation
Y / N	Airflow consistently above 9,000 m3?
Y / N	Flow balanced to both sides of the boiler (damper in correct position)
Y / N	Port plugging
<input type="checkbox"/>	Trend tertiary air pressure (left/right)
DATE: (DD/MM/YY) _____	Date of last cleaning - ONLINE / OFFLINE
<input type="checkbox"/>	Review economizer inlet and outlet temperature trends
	Combustion Air Operation
<input type="checkbox"/>	Damper control or mechanical issues?
<input type="checkbox"/>	Plugged underfire air hoppers?
<input type="checkbox"/>	Feed chute water leaks (leading to poor combustion)
<input type="checkbox"/>	Trend overfire air pressure – front/rear
<input type="checkbox"/>	Trend CO, O ₂ , and combustion air temperature
	Review reagents
<input type="checkbox"/>	Carbon feed rate <ul style="list-style-type: none"> • trend flows, ensure injection points are clear, not slagged over
<input type="checkbox"/>	Lime feed rate <ul style="list-style-type: none"> • trend flows, ensure injection points are clear, not slagged over
<input type="checkbox"/>	Quality of reagents – supplier, physical characteristics,
<input type="checkbox"/>	Trend APC ash analysis trends (titrator)
<input type="checkbox"/>	Test for residual carbon in both APC fly ash streams
<input type="checkbox"/>	Trend dust monitor results on Citect (excessive dust emission may indicate bag failure)
<input type="checkbox"/>	Open baghouse compartment covers and examine for fugitive dust.
<input type="checkbox"/>	Visolite compartments
<input type="checkbox"/>	Open baghouse hopper doors (dirty side) and look for plugged rows
<input type="checkbox"/>	Open baghouse inlet duct and inspect baffle plates for plugging
	Review baghouse trends
<input type="checkbox"/>	Trend Inlet and outlet temperatures. Were there any excursions?
<input type="checkbox"/>	Trend BH DP. Were there periods of excessively low (poor cake thickness) or excessively high (plugged bags) pressure drop?
<input type="checkbox"/>	Trend pulse system operation (non-functional solenoids leading to plugged rows and reduced baghouse efficiency). Were there periods of significant solenoid failures or reduced air pressure?
	Review recirculation hopper trends
<input type="checkbox"/>	Trend temperature deviation trends between recirculation hoppers
<input type="checkbox"/>	Trend airflow vs recirculation rate. Excessively high airflow will overrun the ability of the APC to recirculate sufficient fly ash.

DYEC AMESA – Investigation Checklist

OPERATIONAL FACTORS	
<input type="checkbox"/>	Look for periods of time where combustion airflow caused the recirculation hopper rotary feeders to operate at > 50% speed each or << 40% (recirc rotaries run in the range of 43-49%) at normal combustion air flows
<input type="checkbox"/>	Inspect rotary valves and verify no indication of plugged vanes
<input type="checkbox"/>	Review quench tower trends (inlet/outlet temperature, results of spray lance inspection and cleaning frequency)
<input type="checkbox"/>	Review APC physical operation (status of reactor, quench tower, lime addition equipment, carbon addition equipment)
EQUIPMENT FACTORS	
	Air leakage into process ductwork
Y / N	Plattco valves (superheaters and economizer)
Y / N	Hopper doors, rod out ports
<input type="checkbox"/>	Trend economizer outlet O ₂ and stack O ₂ (Δ)
	Excessive hopper pluggage (from Shift Reports)
Y / N	2 nd pass hopper
Y / N	A1 / A2 / A3 hoppers (Superheaters)
Y / N	APC Recirculation hoppers
<input type="checkbox"/>	Review history of draft fluctuations on superheater and 2 nd pass hoppers (with Plattco cycles)
<input type="checkbox"/>	Review feedwater to steam ratio to determine any potential steam leaks