

The average results for the tests conducted at the Boiler No. 1 BH Outlet and Boiler No. 2 BH Outlet, along with the respective in-stack emission limits, are summarized in the following table:

Parameter	Limit	Boiler No. 1	Boiler No. 2	Combined Boilers
Power Output (MWh/day)	-	-	<u>-</u>	378 <sup>(7)</sup>
Average Combustion Zone Temp. (°C)	_	1216	1246	1231 (8)
Steam (tonnes/day)	-	749	797	1546 <sup>(7)</sup>
MSW Combusted (tonnes/day)	-	189	209	398 <sup>(7)</sup>
NOx Reagent Injection Rate (liters/d)	-	644	1076	1720 (7)
Carbon Injection (kg/day)	-	114	117	231 (7)
Lime Injection (kg/day)	_	3801	4476	8277 <sup>(7)</sup>
Stack Temperature (°C)	-	142	140	141 (8)
Moisture Content (%)	-	16.1	15.6	15.9 <sup>(8)</sup>
Velocity (m/s)	-	16.7	17.3	-
Static Pressure (kPa)	-	-2.76	-2.47	-2.62 <sup>(8)</sup>
Absolute Pressure (kPa)	-	97.9	98.1	98.0 <sup>(8)</sup>
Actual Flowrate (m³/s)	-	24.7	25.6	-
Dry Reference Flowrate (Rm³/s) (1)	-	14.4	15.1	29.5 <sup>(7)</sup>
Oxygen (%)	-	7.38	8.17	7.78 (8)
Carbon Dioxide (%)	*	11.8	11.3	11.6 (8)
Particulate (mg/Rm³) (2)	9	<0.62	<0.48	<0.55 <sup>(8)</sup>
Mercury (μg/Rm³) <sup>(2)</sup>	15	0.44	0.27	0.36 (8)
Cadmium (μg/Rm³) <sup>(2)</sup>	7	<0.043	<0.043	<0.043 (8)
Lead (µg/Rm³) <sup>(2)</sup>	50	0.27	0.22	0.25 (8)
Dioxins and Furans (pg TEQ/Rm <sup>3</sup> ) (3)	60	<818	<12.1	<415 <sup>(8)</sup>
Hydrochloric Acid (mg/Rm³) <sup>(4)</sup>	9	5.6	5.3	5.5 <sup>(8)</sup>
Sulphur Dioxide (mg/Rm³) (4)	35	0.2	0	0.1 (8)
Nitrogen Oxides (mg/Rm³) <sup>(4)</sup>	121	111	111	111 (8)
Total Hydrocarbons (ppm, dry) (5)	50	0.8	0.9	0.9 (8)
Carbon Monoxide (mg/Rm³) (6)	40	22.4	37.5	30.0 (8)

<sup>(1)</sup> dry at 25°C and 1 atmosphere

<sup>(2)</sup> dry at 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

<sup>(3)</sup> calculated using the NATO/CCMS (1989) toxicity equivalence factors and the detection limit for those isomers below the analytical detection limit, dry at 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

<sup>(4)</sup> maximum calculated rolling arithmetic average of 24 hours of data measured by the DYEC CEMS, dry at 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

<sup>(5)</sup> average of six half-hour tests conducted by ORTECH between April 19 and April 20, 2016 measured at an undiluted location, reported on a dry basis expressed as equivalent methane

<sup>(6)</sup> maximum calculated rolling arithmetic average of 4 hours of data measured by the DYEC CEMS, dry at 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

<sup>(7)</sup> total for combined Boilers

<sup>(8)</sup> average for combined Boilers