

Table 1: 2018 Average CEMS readings

Parameter	Limit	Boiler #1	Boiler #2
Opacity	5%	0%	0%
Opacity	10%	0%	1%
Hydrochloric Acid	9 mg/Rm ³	2 mg/Rm ³	3 mg/Rm ³
Sulphur Dioxide	35 mg/Rm ³	0 mg/Rm ³	1 mg/Rm ³
Nitrogen Oxides	121 mg/Rm ³	111 mg/Rm ³	111 mg/Rm ³
Carbon Monoxide	40 mg/Rm ³	14 mg/Rm ³	13 mg/Rm ³
Oxygen	Minimum 6%	8%	8%
Furnace Temperature	Minimum 1000 °C	1247 °C	1272 °C
Baghouse Inlet Temperature	>120 <185 °C	143 °C	143 °C